

Certificate

of
Continued Compliance

No: 162350032/AA/03

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **Wireless PIR detector 12m 433 MHz**
Trademark: **Interlogix**
Type designation: **RF-EV1012-K4**
Serial No: **N/A**
Hardware / Software version: **55-1007-F / V1.01**
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

Expiry date: **18 August 2024**

This certificate has THREE Annexes.

Zevenaar, 18 August 2020



Marcellino Jansen
Test Engineer





Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.
Electromagnetic emission and safety aspects are not covered by this certificate.



Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 150902090-009-Ver 5.00, 16 October 2018
- Telefication: 150902083-013-Ver 1.00, 29 June 2016
- Telefication: 160901041-001-Ver. 1.00, 06 February 2017
- Telefication B.V.: 200200029-001-Ver. 1.00, 17 March 2020
- Telefication B.V.: 200401502-002-Ver 2.00, 29 July 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2	November, 2017
EN 50131-5-3	March, 2017

Applied Standards

EN 50130-5	June, 2011
EN 50131-6	October, 2017
EN 50131-1+A1+A2	May, 2017
EN 50130-4+A1	October, 2014

The product as described in this certificate includes the following type designations:

- Product description: Wireless PIR detector 12m 433 MHz
- Trademark: Interlogix
- Type designation: RF-EV1012-K4
- Hardware version: 55-1007-F
- Software version: V1.01
- Serial number: N/A

- Product description: Wireless PIR detector 12m PI 433 MHz
- Trademark: Interlogix
- Type designation: RF-EV1012PI-K4
- Hardware version: 55-1007-F
- Software version: V1.01
- Serial number: N/A

- Product description: Wireless PIR detector 12m 868 MHz
- Trademark: Interlogix
- Type designation: TX-2213-03-1
- Hardware version: 55-1007-F
- Software version: V1.01
- Serial number: N/A

- Product description: Wireless PIR detector 12m PI 868 MHz
- Trademark: Interlogix
- Type designation: RF-EV1016-K4
- Hardware version: 55-1007-F
- Software version: V1.01
- Serial number: N/A

- Product description: Wireless PIR detector 16m 433 MHz
- Trademark: Interlogix
- Type designation: TX-2214-03-1
- Hardware version: 55-1007-F
- Software version: V1.01
- Serial number: N/A

- Product description: Wireless PIR detector 16m 868 MHz
- Trademark: Interlogix
- Type designation: TX-2311-03-1
- Hardware version: 55-1007-F
- Software version: V1.01
- Serial number: N/A